



PIPE BACKFILL DETAILS
IN EASEMENTS
NOT TO SCALE

PIPE BACKFILL DETAILS

1. ALL PIPES LOCATED UNDER STRUCTURES SUCH AS SHEDS, GARAGES, Etc., DRIVEWAYS OR PAVED AREAS ARE TO BE BACKFILLED TO THE UNDERSIDE OF THE STRUCTURE OR PAVING WITH CLASS 3 20mm Nom. CRUSHED ROCK.
2. COMPACTION OF ALL PIPE BACKFILL ZONES TO BE TO COUNCILS STANDARD SPECIFICATIONS FOR ROAD AND DRAINAGE WORKS

KINGSTON CITY COUNCIL
STANDARD DRAWING

PIPE BACKFILL DETAIL EASEMENTS

DRG. NO. S506

ISSUE DATE: 22/03/12

STANDARD DRAWING ISSUE
CURRENT AT TIME OF
CONSTRUCTION MUST BE USED